



Ref. Certif. No.

SE-113848

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Nano 2 Relay Tree

Name and address of the applicant

Loxone Electronics GmbH
Smart Home 1, AT-4154 Kollerschlag
AUSTRIA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Additional Information on page 2

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

Control side: 18Vdc to 28Vdc
Load side: 250Vac, 50/60Hz, Max.10A each way, Max. 12A in total, Resistive 30Vdc, Max.10A each way, Max. 12A in total, Resistive

Trademark / Brand (if any)



Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

100395

Additional information (if necessary may also be reported on page 2)

Additional Information on page 2

A sample of the product was tested and found to be in conformity with

IEC 60730-1:2013+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

220701097SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Torshamnsgatan 43
Box 1103
SE-164 22 Kista, Sweden



Date: 26 April, 2024

Signature:

Hyden Li